



Goodwyn Mills Cawood  
11 North Water Street  
Suite 19290  
Mobile, Alabama 36602  
T 251.460.4006  
F 251.460.4423

## TRANSMITTAL COVER SHEET

**DATE:** December 9, 2024  
**PAGE:** 1 of 2 (INCLUDING THIS PAGE)  
**TO:** ALL CONTRACTORS  
**FROM:** ROBBIE STROM  
**PROJECT:** 1200 BLOCK OF BIENVILLE BLVD DRAINAGE REPAIR  
FOR THE TOWN OF DAUPHIN ISLAND  
GMC PROJECT NO. CMOB240044  
**RE:** ADDENDUM #1

**PLEASE COMPLETE BELOW AND RETURN IMMEDIATELY.**

Ashley Morris  
Email: [Ashley.Morris@gmcnetwork.com](mailto:Ashley.Morris@gmcnetwork.com)

I, the undersigned, hereby acknowledge receipt of this Addendum.

\_\_\_\_\_  
Authorized Representative of Contractor

\_\_\_\_\_  
Date

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Telephone

\_\_\_\_\_  
Contractor's License Number (if applicable)



# ADDENDUM NUMBER 1

---

1200 BLOCK OF BIENVILLE BLVD DRAINAGE REPAIR

FOR

THE TOWN OF DAUPHIN ISLAND

GMC PROJECT NO. CMOB240044

## 1. Revisions to Project Manual

- 1.1 The following revisions are hereby added as Addendum No. 1 to the referenced Project Manual and Plans and shall be considered when preparing bids.

## 2. Contractor Questions

- 2.1 **Is this one tax exempt?**  
Yes, this work is tax exempt.
- 2.2 **This is a replacement project but there is no pipe removal?**  
Pipe removal is to be subsidiary condition of item 2, Unclassified Excavation.
- 2.3 **Is the asphalt patch 2" thick or 3" thick? Pay item shows 2" but typical shows 3"**  
Asphalt patch shall be installed in accordance with the detail on sheet C-901.
- 2.4 **Where does the Minor Structure Concrete go? Around the pipes at tie-ins?**  
Minor Structure Concrete is an incidental item that will be used as needed. If not needed during construction it will not be used.
- 2.5 **Is Does the Roady Pipe need to be a Class 3 and not Class 2?**  
Class 3 RCP pipe is required. Disregard the note on the bid form description.

## 3. Acknowledgement of Receipt

- 3.1 Receipt of Addendum shall be acknowledged in two ways:
- 3.1.1 Note on (EJCDC C-410) Bid Form of the Project Manual – Bidder acknowledges receipt of “Addendum No. 1” and date of “December 9, 2024”.
- AND**
- 3.1.2 EMAIL GMC [ashley.morris@gmcnetwork.com](mailto:ashley.morris@gmcnetwork.com) with the signed transmittal which confirms the addendum has been received and is legible.

## 4. Conclusion

- 4.1 This is the end of Addendum Number 1, dated Monday, December 9, 2024.